

What's New April 2019

Contents

Section 1. Summary

Section 2. Detailed Content Changes

This document contains a full record of all content revisions contained within the April 2019 Design Suite content update. To apply content updates to your application follow the below instructions.

[Automatic data updates](#) are user defined within the 'Check for Updates' tab under 'Application Settings'. Once applied, a check will be made for a new package upon every launch of the application. If a new package is found, you will be prompted to install it now or later. Once installed, the application will be restarted.

[Manual data updates](#) are run at users' discretion. If your application is not set to automatically check for data updates, you can manually check by going to the 'Check for Updates' tab under 'Application Settings' and clicking 'Check Now'. If a new package is found, you will be prompted to install it now or later. Once installed, the application will be restarted.

Section 1	Summary
New Content	Circuit Protective Devices: ABB Dorman Smith Eaton Legrand
Modified Content	Busbars Legrand (Zucchini) Circuit Protective Devices: ABB Dorman Smith

See Section 2 for details

Section 2 Detailed Content Changes

Busbars

Legrand (Zucchini)

- Modified content – Update to MS, MR & MRf fault current rating and short time withstand.

Circuit Protective Devices

ABB

- New content – Addition of DSE201 RCBO range
- Modified content – S200 Time/Current curve & device selector update

Dorman Smith

- New content – Addition of KR RCBO range
- Modified content – K-Line AA MCCB thermal curve update

Eaton

- New content – NZM/IZMX Selectivity & Back Up data

Legrand

- New content – addition of new DPX3 adjustable Th/Mag and Electronic MCCBs. Available in a 160A, 250A & 630A frame sizes and 16kA, 25kA, 36kA, 50kA, 70kA & 100kA breaking capacities.