

What's New July 2018

Contents

Section 1. Summary

Section 2. Detailed Content Changes

This document contains a full record of all content revisions contained within the May 2018 Design Suite content update. To apply content updates to your application follow the below instructions.

[Automatic data updates](#) are user defined within the 'Check for Updates' tab under 'Application Settings'. Once applied, a check will be made for a new package upon every launch of the application. If a new package is found, you will be prompted to install it now or later. Once installed, the application will be restarted.

[Manual data updates](#) are run at users' discretion. If your application is not set to automatically check for data updates, you can manually check by going to the 'Check for Updates' tab under 'Application Settings' and clicking 'Check Now'. If a new package is found, you will be prompted to install it now or later. Once installed, the application will be restarted.

Section 1	Summary
New Content	Busbars: Schneider Circuit Protective Devices: Generic
Modified Content	Cables: Prysmian

See Section 2 for details

Section 2 Detailed Content Changes

Busbars

Schneider

- New content – Addition of new Copper KSC busbars, available in 160A to 800A ratings and new Aluminium KSA busbars, available in 100A to 1000A ratings.

Cables

Prysmian

- Modified content
 - Pirelli name changed to Prysmian
 - LSX Cable now uses 90° Thermosetting data from table 4B1 in BS7671.
 - FP600S Fire Resistant Cable now has Reference Method D installation methods available for selection.
 - Draka FT30 now has Reference Method E installation methods available for selection.
 - Draka Railsure, Draka L-Sifer and Prysmian FP100 now have Reference Method F installation methods available for selection.

Circuit Protective Devices

Generic

- New content – addition of new Generic adjustable and fixed Th/Mag MCCBs. Available in a 160A frame size and 16kA, 25kA, 36kA, 50kA & 70kA breaking capacities.